COPY ISSUED BY\_\_\_\_\_ NON-CONTROLLED CORY INFORMATION SUBJECT TO CHANGE WITHOUT NOTICE CORY ISSUED DN\_\_\_\_\_\_ COPY WILL NOT BE UPDATED NOZZLE SCHEDULE & ACCESSORIES SERVICE | MK ISTOCK NO.ISIZE DEG ELEV STIFFENER DETAIL (14) PLACES SCALE: 3'=1'-0' 1. THIS IS A COMPUTER GENERATED DWG. DO NOT REVISE BY HAND. DIMENSIONS WILL VARY ±3% DUE TO VARIATIONS IN MULTIPLE MOLDS & CONDITIONS PREVELANT DURING MANUFACTURE & USAGE. 3. NO GALLONAGE MARKERS THIS TANK. PLAN STIFFFNER 11 1/2\* CALCULATED CAPACITIES/ SEE DTL TYP TYP CONFIDENTIAL PROPERTY OF VOLUME IN U.S. GALLONS POLY PROCESSING COMPANY NOT FOR REPRINT OR USE WITHOUT PERMISSION DESIGN CAPACITY SIDE **ELEVATION** 320 GALLON RECTANGULAR SECONDARY CONTAINMENT SCALE 3/4'=1'-0' PROCESSING NOTE: CAPACITIES OF RECTANGULAR SECONDARY CONTAINMENT BASINS Dentral Region Fig. Res 408 Fig. 1989 BR WILKERSON CK. D. RECTOR MAY BE SIGNIFICANTLY LESS THAN NOMINAL VOLUME WITHOUT ADEQUATE EXTERNAL SUPPORT. COMPUTER FILE 1 DF 1 5100320